



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
 Phone: 919-733-7308
 Fax: 919-715-8611

FINAL REPORT

Report to: Environmental Health

Name of System:

HENDERSON CO ENVIRONMENTAL HEALTH
 1200 SPARTANBURG HWY - STE 100
 Hendersonville, NC 28792

Jason Yocum
 29 Melody Ln
 Mills River, NC 28759

EIN: 566000307EH

Delivery: NC Courier

Henderson County

StarLiMS ID: **N260057-0079**

Date Collected: 02/25/2026

Time Collected: 08:45

By: Quinton Powell

Date Received: 02/26/2026

Time Received: 08:36

By: Angela Heybroek

Sample Desc: New Well

Sampling Point: Well head

Sample Source: Raw

GPS No.

Treatment:

Well Permit No. OSS-2024-0426

Comment:

Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Present			02/26/2026
E. coli	Absent			02/26/2026

Report Date: 03/02/2026

Reported By: **KKURTZ**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.