



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918
 http://slph.ncpublichealth.com
 Phone: 919-733-7308
 Fax: 919-715-8611

FINAL REPORT

Report to: Kelsey Ellis

Name of System:

WILMINGTON REGIONAL OFFICE PWSS
 127 CARDINAL DRIVE EXTENSION
 Wilmington, NC

Blue Clay Rd Business Park
 1901 Blue Clay Rd
 Wilmington, NC 28401

EIN: 562033372Q

Delivery: NC Courier

New Hanover County

StarLiMS ID: N260097-0057	Date Collected: 04/06/2026	Time Collected: 13:21	By: Kelsey Ellis
	Date Received: 04/07/2026	Time Received: 08:28	By: DeMonta Newborn
Water System ID: 04-65-625	System Type: NTNC	Water Source: Ground Water	
Facility ID:		Sample Type: Special/Non-Compliance	
Sample Location: Treatment room	Location Type: E01	Location Code:	
Disinfectant Used:	Free Chlorine:	Total Chlorine:	

Comments:

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Present			04/07/2026
E. coli	Absent			04/07/2026

Report Date: 04/09/2026

Reported By: TOWENS2

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.