



**North Carolina State Laboratory of Public Health**  
*Environmental Sciences*  
**Microbiology**  
**Certificate of Analysis**

4312 District Drive  
 MSC 1918  
 Raleigh, NC 27699-1918  
 http://slph.ncpublichealth.com  
 Phone: 919-733-7308  
 Fax: 919-715-8611

**FINAL REPORT**

**Report to: Kelsey Ellis**

**Name of System:**

**WILMINGTON REGIONAL OFFICE PWSS**  
 127 CARDINAL DRIVE EXTENSION  
 Wilmington, NC

**Blue Clay Rd Business Park**  
 1901 Blue Clay Rd  
 Wilmington, NC 28401

**EIN: 562033372Q**

**Delivery: NC Courier**

**New Hanover County**

StarLiMS ID: **N260097-0060**

Date Collected: 04/06/2026

Time Collected: 13:19 By: Kelsey Ellis

Date Received: 04/07/2026

Time Received: 08:29 By: DeMonta Newborn

Water System ID: 04-65-625

System Type: NTNC

Water Source: Ground Water

Facility ID:

Sample Type: Special/Non-Compliance

Sample Location: Raw water tap

Location Type: RW 1

Location Code:

Disinfectant Used:

Free Chlorine:

Total Chlorine:

Comments:

**PWS - Colisure Profile**

**Method: SM 9223B**

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			04/07/2026
E. coli	Absent			04/07/2026

**Report Date:** 04/09/2026

**Reported By:** TOWENS2

**Explanations of Coliform Analysis:**

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.