



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918
 http://slph.ncpublichealth.com
 Phone: 919-733-7308
 Fax: 919-715-8611

FINAL REPORT

Report to: TAYLOR SLOOP

Name of System:

HENDERSON CO ENVIRONMENTAL HEALTH
 1200 SPARTANBURG HWY - STE 100
 Hendersonville, NC 28792

Christopher & Stacy Fields
 176 Carnelian Dr
 Fletcher, NC 28732

EIN: 566000307EH

Delivery: NC Courier

Henderson County

StarLiMS ID: **N260113-0055**

Date Collected: 04/22/2026

Time Collected: 09:04

By: Taylor Sloop

Date Received: 04/23/2026

Time Received: 08:22

By: Angela Heybroek

Sample Desc: New Well

Sampling Point: Well head

Sample Source: Raw

GPS No.

Treatment:

Well Permit No. OSS-2023-1746

Comment:

Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			04/23/2026
E. coli	Absent			04/23/2026

Report Date: 04/27/2026

Reported By: TOWENS2

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.