



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
 Phone: 919-733-7308
 Fax: 919-715-8611

FINAL REPORT

Report to: Mark Brown

Name of System:

WILMINGTON REGIONAL OFFICE PWSS
 127 CARDINAL DRIVE EXTENSION
 Wilmington, NC

Town of Wallace
 304 Murray St
 Wallace, NC 28466

EIN: 562033372Q

Delivery: NC Courier

Duplin County

StarLiMS ID: N260127-0028	Date Collected: 05/06/2026	Time Collected: 09:52	By: Mark Brown
	Date Received: 05/07/2026	Time Received: 07:53	By: Cille Tutherow
Water System ID: 04-31-010	System Type: C	Water Source: Ground Water	
Facility ID:		Sample Type: Routine	
Sample Location: Outdoor hose bib	Location Type: 503	Location Code:	
Disinfectant Used:	Free Chlorine:	Total Chlorine:	

Comments:

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			05/07/2026
E. coli	Absent			05/07/2026

Report Date: 05/13/2026

Reported By: **DNEWBORN**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.