



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918
 http://slph.ncpublichealth.com
 Phone: 919-733-7308
 Fax: 919-715-8611

FINAL REPORT

Report to: Kelsey Ellis

Name of System:

WILMINGTON REGIONAL OFFICE PWSS
 127 CARDINAL DRIVE EXTENSION
 Wilmington, NC

CIR - RV Park

EIN: 562033372Q

Delivery: NC Courier

Carteret County

StarLiMS ID: N260154-0036	Date Collected: 06/02/2026	Time Collected: 11:45	By: Kelsey Ellis
	Date Received: 06/03/2026	Time Received: 07:53	By: DeMonta Newborn
Water System ID: 70-16-037	System Type: NTNC	Water Source: Ground Water	
Facility ID:		Sample Type: Special/Non-Compliance	
Sample Location:	Location Type: 009	Location Code: Lot 9	
Disinfectant Used:	Free Chlorine:	Total Chlorine:	

Comments: Disinfectant Used: None

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Present			06/03/2026
E. coli	Absent			06/03/2026

Report Date: 06/05/2026

Reported By: **DNEWBORN**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.