



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
 Phone: 919-733-7308
 Fax: 919-715-8611

FINAL REPORT

Report to: Kelsey Ellis

Name of System:

WILMINGTON REGIONAL OFFICE PWSS
 127 CARDINAL DRIVE EXTENSION
 Wilmington, NC

CIR - Motel

EIN: 562033372Q

Delivery: NC Courier

Carteret County

StarLiMS ID: **N260154-0037**

Date Collected: 06/02/2026

Time Collected: 12:10 By: Kelsey Ellis

Date Received: 06/03/2026

Time Received: 07:54 By: DeMonta Newborn

Water System ID: 04-16-422

System Type:

Water Source: Ground Water

Facility ID:

Sample Type: Special/Non-Compliance

Sample Location: Motel hose bib

Location Type: 001

Location Code:

Disinfectant Used:

Free Chlorine:

Total Chlorine:

Comments: Disinfectant Used: None

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Present			06/03/2026
E. coli	Absent			06/03/2026

Report Date: 06/05/2026

Reported By: **DNEWBORN**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.