



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
 Phone: 919-733-7308
 Fax: 919-715-8611

FINAL REPORT

Report to: Doug Whitmire

Name of System:

WINSTON SALEM REGIONAL OFFICE PWSS
 450 WEST HANES MILL RD STE 300
 Winston Salem, NC 27105

Kelly's 49

EIN: 566000372X

Delivery: NC Courier

Randolph County

StarLiMS ID: N260161-0034	Date Collected: 06/09/2026	Time Collected: 13:11	By: Doug Whitmire
	Date Received: 06/10/2026	Time Received: 08:00	By: DeMonta Newborn
Water System ID: 30-76-001	System Type: NTNC	Water Source: Ground Water	
Facility ID:		Sample Type: Special/Non-Compliance	
Sample Location: 3 Compartment Sink	Location Type:	Location Code: 3CS	
Disinfectant Used:	Free Chlorine:	Total Chlorine:	

Comments: Dinsintectant Used: None

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Present			06/10/2026
E. coli	Absent			06/10/2026

Report Date: 06/11/2026

Reported By: **DNEWBORN**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.