



**North Carolina State Laboratory of Public Health**  
*Environmental Sciences*  
**Microbiology**  
**Certificate of Analysis**

4312 District Drive  
 MSC 1918  
 Raleigh, NC 27699-1918  
<http://slph.ncpublichealth.com>  
 Phone: 919-733-7308  
 Fax: 919-715-8611

**FINAL REPORT**

**Report to:** Leo Farua

**Name of System:**

**HENDERSON CO ENVIRONMENTAL HEALTH**  
 1200 SPARTANBURG HWY - STE 100  
 Hendersonville, NC 28792

**Grayson Luanter**  
 111 Tullahoma Farms Ln  
 Hendersonville, NC 28792

**EIN:** 566000307EH

**Delivery:** NC Courier

**Henderson County**

StarLiMS ID: **N260175-0004**

Date Collected: 06/23/2026

Time Collected: 08:55

By: LF

Date Received: 06/24/2026

Time Received: 07:56

By: Cille Tutherow

Sample Desc: Well water

Sampling Point: Tap In Kitchen

Sample Source:

GPS No.

Treatment:

Well Permit No. N/A

Comment:

**Colilert Profile**

**Method: SM 9223B**

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			06/24/2026
E. coli	Absent			06/24/2026

**Report Date:** 06/26/2026

**Reported By:** **DNEWBORN**

**Explanations of Coliform Analysis:**

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.