



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
MSC 1918
Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

FINAL REPORT

Report to: Doug Whitmire

Name of System:

WINSTON SALEM REGIONAL OFFICE PWSS
450 WEST HANES MILL RD STE 300
Winston Salem, NC 27105

English Rose Coffee and Tea Hous

EIN: 566000372X

Delivery: NC Courier

Guilford County

StarLiMS ID: **N260188-0042** Date Collected: 07/06/2026 Time Collected: 10:55 By: Doug Whitmire
Date Received: 07/07/2026 Time Received: 08:10 By: Cille Tutherow
Water System ID: 30-41-145 System Type: NTNC Water Source: Ground Water
Facility ID: Sample Type: Special/Non-Compliance
Sample Location: Kitchen Sink Location Type: Location Code: KS1
Disinfectant Used: Free Chlorine: Total Chlorine:

Comments:

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Present			07/07/2026
E. coli	Absent			07/07/2026

Report Date: 07/09/2026

Reported By: **DNEWBORN**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.