



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
MSC 1918
Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

FINAL REPORT

Report to: Blair Murray

Name of System:

MOORESVILLE REGIONAL OFFICE PWSS
610 EAST CENTER AVENUE
Mooresville, NC 28115

DOT I85-Weigh Station

EIN: 566000037AA

Delivery: NC Courier

Gaston County

StarLiMS ID: N260189-0019	Date Collected: 07/07/2026	Time Collected: 11:15	By: Blair Murray
	Date Received: 07/08/2026	Time Received: 08:05	By: Cille Tutherow
Water System ID: 20-36-036	System Type: NTNC	Water Source: Ground Water	
Facility ID: D01		Sample Type: Special/Non-Compliance	
Sample Location: Kitchen Sink	Location Type:	Location Code: 006	
Disinfectant Used:	Free Chlorine: N/A mg/L	Total Chlorine: N/A mg/L	

Comments:

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			07/08/2026
E. coli	Absent			07/08/2026

Report Date: 07/10/2026

Reported By: DNEWBORN

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.