



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
MSC 1918
Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

FINAL REPORT

Report to: Doug Whitmire

Name of System:

WINSTON SALEM REGIONAL OFFICE PWSS
450 WEST HANES MILL RD STE 300
Winston Salem, NC 27105

RCC Emergency Services Training

NC

EIN: 566000372X

Delivery: NC Courier

Randolph County

StarLiMS ID: **N260265-0067** Date Collected: 09/21/2026 Time Collected: 09:40 By: Doug Whitmore
Date Received: 09/22/2026 Time Received: 09:40 By: Jake Suminguit
Water System ID: 30-76-039 System Type: NC Water Source:
Facility ID: Sample Type: Special/Non-Compliance
Sample Location: Room 100 Location Type: Location Code: 100
Disinfectant Used: Free Chlorine: Total Chlorine:

Comments:

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Present			09/22/2026
E. coli	Absent			09/22/2026

Report Date: 09/24/2026

Reported By: **DNEWBORN**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.