



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
MSC 1918
Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

FINAL REPORT

Report to: Joe Holder

Name of System:

WINSTON SALEM REGIONAL OFFICE PWSS
450 WEST HANES MILL RD STE 300
Winston Salem, NC 27105

Bur-Mil Park

NC

EIN: 566000372X

Delivery: NC Courier

Guilford County

StarLiMS ID: **N260274-0028** Date Collected: 09/30/2026 Time Collected: 10:05 By: Joe Holder
Date Received: 10/01/2026 Time Received: 08:07 By: Cille Tutherow
Water System ID: NC 02-41-560 System Type: NC Water Source: Ground Water
Facility ID: D01 Sample Type: Special/Non-Compliance
Sample Location: Location Type: Location Code:
Disinfectant Used: Free Chlorine: Total Chlorine:

Comments:

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			10/01/2026
E. coli	Absent			10/01/2026

Report Date: 10/05/2026

Reported By: DNEWBORN

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.