



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
MSC 1918
Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

FINAL REPORT

Report to: Mark Brown

Name of System:

WILMINGTON REGIONAL OFFICE PWSS
127 CARDINAL DRIVE EXTENSION
Wilmington, NC

Grace Presbyterian Church
2101 Live Oak St
Beaufort, NC

EIN: 562033372Q

Delivery: NC Courier

Carteret County

StarLiMS ID: N260287-0022

Date Collected: 10/13/2026

Time Collected: 10:03 By: Kelsey Ellis

Date Received: 10/14/2026

Time Received: 08:06 By: DeMonta Newborn

Water System ID: 04-16-508

System Type: NC

Water Source: Ground Water

Facility ID:

Sample Type: Special/Non-Compliance

Sample Location: Nursery RR

Location Type:

Location Code: 012

Disinfectant Used:

Free Chlorine:

Total Chlorine:

Comments:

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			10/14/2026
E. coli	Absent			10/14/2026

Report Date: 10/16/2026

Reported By: DNEWBORN

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.