4312 District Drive
MSC 1918
Raleigh, NC 27699-1918

http://slph.ncpublichealth.com
Phone: 919-733-7308
Fax: 919-715-8611

North Carolina State Laboratory of Public Health

Environmental Sciences

Microbiology

Certificate of Analysis

FINAL REPORT

Report to: **Doug Whitmire**

WINSTON SALEM REGIONAL OFFICE PWSS
450 WEST HANES MILL RD STE 300
Winston Salem, NC 27105

Name of System:

Snack & Soda #4

NC

EIN: **566000372X** **Delivery:** **NC Courier** **Guilford County**

StarLiMS ID: **N260302-0038**

Date Collected: 10/28/2026 Time Collected: 15:20 By: Doug Whitmire
Date Received: 10/29/2026 Time Received: 08:19 By: Tyler Owens

Water System ID: 02-41-675 System Type: NC Water Source: Ground Water
Facility ID: Sample Type: Special/Non-Compliance

Sample Location: 3 Compartment Sink Location Type: Location Code: 3CS
Disinfectant Used: Free Chlorine: Total Chlorine: 0.0 mg/L

Comments: No disinfectant used

PWS - Colisure Profile **Method: SM 9223B**

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			10/29/2026
E. coli	Absent			10/29/2026

Report Date: 10/30/2026 **Reported By:** **DNEWBORN**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.